CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-20-01** **Date: 23-02-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements & Construction of CC Road Jain temple 1st, 2nd, 3rd, 4th & 5th Cross roads MTS Colony main Road at Ward No.15 Dasarahalli.(2nd Call)

Customer's Reference : EE/DD/WO/112/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 20-02-17

Sample ID No : 2017-02-20-01/01

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 7

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/02/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	15/02/2017	22/02/2017	150.76 X 149.43 X 150.66	22528	8.154	542.9	24.1	24.3
2	Cement Concrete Road	M30	15/02/2017	22/02/2017	149.25 X 150.27 X 150.74	22428	8.106	551.7	24.6	
3	Cement Concrete Road	M30	15/02/2017	22/02/2017	151.90 X 150.65 X 150.26	22884	8.129	556.1	24.3	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-20-02** **Date: 24-02-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements & Construction of CC Road Jain temple 1st, 2nd, 3rd, 4th & 5th Cross roads MTS Colony main Road at Ward No.15 Dasarahalli.(2nd Call)

Customer's Reference : EE/DD/WO/112/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 20-02-17

Sample ID No : 2017-02-20-02/01

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 7

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/02/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	16/02/2017	23/02/2017	151.02 X 149.87 X 150.22	22633	8.177	538.7	23.8	24.1
2	Cement Concrete Road	M30	16/02/2017	23/02/2017	149.81 X 150.41 X 150.87	22533	8.167	556.6	24.7	
3	Cement Concrete Road	M30	16/02/2017	23/02/2017	150.28 X 150.77 X 150.81	22658	8.175	541.5	23.9	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-20-03** **Date: 25-02-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements & Construction of CC Road Jain temple 1st, 2nd, 3rd, 4th & 5th Cross roads MTS Colony main Road at Ward No.15 Dasarahalli.(2nd Call)

Customer's Reference : EE/DD/WO/112/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 20-02-17

Sample ID No : 2017-02-20-03/01

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 7

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 24/02/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	17/02/2017	24/02/2017	149.09 X 151.86 X 150.44	22641	8.198	561.5	24.8	24.3
2	Cement Concrete Road	M30	17/02/2017	24/02/2017	150.61 X 150.27 X 150.66	22632	8.154	540.9	23.9	
3	Cement Concrete Road	M30	17/02/2017	24/02/2017	151.72 X 150.38 X 150.81	22816	8.147	554.4	24.3	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-23-01** **Date: 25-02-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements & Construction of CC Road Jain temple 1st, 2nd, 3rd, 4th & 5th Cross roads MTS Colony main Road at Ward No.15 Dasarahalli.(2nd Call)

Customer's Reference : EE/DD/WO/112/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 23-02-17

Sample ID No : 2017-02-23-01/01

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 7

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/02/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	18/02/2017	25/02/2017	150.22 X 150.76 X 149.64	22647	8.109	541.3	23.9	23.7
2	Cement Concrete Road	M30	18/02/2017	25/02/2017	150.22 X 150.76 X 150.62	22647	8.111	523.1	23.1	
3	Cement Concrete Road	M30	18/02/2017	25/02/2017	150.88 X 150.28 X 150.16	22674	8.152	548.7	24.2	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL|
GEO TECHNICAL| PROJECT MANAGEMENT| SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-02-23-01** **Date: 18-03-17**

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Sri Gnanendra Murthy M.D, #410, 5th Main Road, 4th Cross, Kengeri Satelite Town, Bangalore.

Project Name : Improvements & Construction of CC Road Jain temple 1st, 2nd, 3rd, 4th & 5th Cross roads MTS Colony main Road at Ward No.15 Dasarahalli.(2nd Call)

Customer's Reference : EE/DD/WO/112/16-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 23-02-17

Sample ID No : 2017-02-23-01/02

Customer ID : Cement Concrete Road

Sample Type /Size : 150X150X150mm

Sample grade/Age : M30 / 28

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 18/03/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Road	M30	18/02/2017	18/03/2017	149.27 X 150.28 X 150.62	22432	8.117	767.2	34.2	33.7
2	Cement Concrete Road	M30	18/02/2017	18/03/2017	151.91 X 150.12 X 150.11	22805	8.108	757.1	33.2	
3	Cement Concrete Road	M30	18/02/2017	18/03/2017	150.98 X 151.09 X 150.28	22812	8.165	768.7	33.7	

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/ Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 8861262858 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |